



**NOTES:**

- ALL GREASE INTERCEPTORS ARE SIZED BASED ON 20 GALLON PER SEAT / PER BED
- GREASE INTERCEPTOR SIZING: MINIMUM – 1000 GALLONS, MAXIMUM – 2000 GALLONS.
- NOTE: IF MORE TANKS ARE REQUIRED, THEN TWO OR MORE TANKS MUST BE INSTALLED IN SERIES
- ALL GREASE INTERCEPTORS MUST BE INSTALLED WITH LOCKING METAL RINGS AND COVERS
- GREASE INTERCEPTORS SHOULD BE INSTALLED IN A NON-TRAFFIC AREA, BUT IF THEY ARE NOT, TRAFFIC RATED TOPS WILL BE REQUIRED
- AVOID INSTALLING GI IN THE DRIVE-THRU LANE
- DO NOT INSTALL GREASE INTERCEPTORS NEAR GARBAGE CONTAINMENT AREAS
- AN AVAILABLE HOSE BIB MUST BE INSTALLED FOR CLEAN OUT PURPOSES BY A HAULER
- FOOD GRINDERS MUST NOT BE CONNECTED TO GREASE INTERCEPTORS – ALL KITCHEN WASTE SHOULD BE DISPOSED OF IN GARBAGE CONTAINER
- MOP SINKS, FLOOR DRAINS, 3-COMP SINKS, AND PRE-RINSE BASIN ONLY FROM DISHWASHER MUST BE CONNECTED TO THE GREASE INTERCEPTOR
- ICE MACHINES, HAND SINKS, TEA/SODA STATIONS, PREP SINKS, AND THE OUTPUT OF THE DISHWASHER MUST GO TO THE SANITARY LINE
- MUST BE APPROVED BY CWR PRETREATMENT APPLICATION AVAILABLE AT: [WWW.CMDCSD.COM](http://WWW.CMDCSD.COM)



Chester County  
Wastewater Recovery  
3261 Lancaster Hwy.  
Richburg, SC 29729  
Phone: (803) 377-3541

**GREASE TRAP**

SCALE: N.T.S.

DATE: 05-20-2014

DETAIL No.	
S-39.0	
REV.	DATE
1	12/14/2017